

Prasar Bharti  
Broadcasting Corporation of India,  
Office of the Assistant Engineer (E)  
CCW:AIR, DDB Phase-II, Copernicus Marg, Mandi House  
New Delhi - 110 001.

No. 14(2)/AE(E)/MH-II/2010-11/32

Date : 10-6-2010

**Notice Invitation Quotation**

Sealed quotation are invited on behalf of President of India on item rate for the item noted supply / work so as to reach to undersigned on or before 17-6-2010 by 3.00 p.m.

The quotation shall be opened on the same day at 3.30 p.m. The quotation should be subscribed Quotation for (\*) due on 17-6-2010

(\*)Name of Work : **Providing and Fixing exhaust fan and duct for ferro ammonia printer machine in room no. 925 at DDB Tower "B", Mandi House, New Delhi.**

S/N.	Description of Item	Qty.	Rate	Unit	Amount
------	---------------------	------	------	------	--------

--- As per schedule of work attached---

**Terms & Conditions :**

1. The Work shall be carried out as per CPWD specification.
2. The rates quoted by the agency should be net & inclusive of all taxes & cartage, octroi. No advance payment shall be made on this account.
3. Time allowed for completion of work is 05 days.
4. The dismantled material should be returned to JE(E) concerned if any.
5. The undersigned reserved the right to reject any or all the quotation without assigning any reason.

Issued to : \_\_\_\_\_

Assistant Engineer(E)

Copy to :

- 1) The Superintending Engineer, AIR, 6<sup>th</sup> floor, NBH, Sansad Marg, New Delhi with the request to upload this tender notice at All India Radio, tender website.
- 2) The Executive Engineer(E)-II, CCW:AIR, Pushpa Bhawan, New Delhi.
- 3) Notice Board

*[Signature]*  
15/06/10  
Asstt. Engineer (E)  
CCW: AIR, Dourdarshan Bhawan  
Mandi House, Phase-II, New Delhi-1

### Schedule of Work

Name of work : Pdg. and Fixing exhaust fan and duct for ferro amonia printer machine in room no. 925 at DDB Tower "B", Mandi House, New Delhi.

S/N	Name of Work	Qty.	Unit	Rate	Amount
1	Wiring for light point / fan point / exhaust fan point / call bell point with 1.5 sqmm FR PVC insulated copper conductor single core cable in surface / recessed <u>Steel conduit</u> , with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sqmm FR PVC insulated copper conductor single core cable etc. complete as required - Group "C"	1	Points	Pts.	
2	SITC of heavy duty 900 rpm exhaust fan of size 300 mm suitable for operation on 230 V single phase in the existing opening etc. as reqd. (Make : Crompton / Khaitan)	1	No.	Each	
3	Making necessary arrangement for fixing the exhaust (300 mm) in the glass window i/c cutting the alu. Section and glass to suit the size etc. complete as required & as per direction of Engineer-in-charge.	1	Job	Job	
4	Supplying & Fixing duct of size 6" x 6" of length 6" approx with elbow made from 22 gauge GI sheet etc. complete as required & as per direction of Engineer-in-charge.	1	Job	Job	
<b>Grand Total</b>					

  
Assistant Engineer (E)  
CCW, AIR, Doordarshan Bhawan  
Mandi House, Phase-II, New Delhi-1