

PRASAR BHARATI
(INDIA'S PUBLIC SERVICE BROADCASTER)
OFFICE OF THE ADDITIONAL DIRECTOR GENERAL(E)(EZ)
ALL INDIA RADIO & DOORDARSHAN


No. P/1/ E-Tender / 40 KVA UPS/18-19

Akashvani Bhavan, 4th floor,
Eden Gardens, Kolkata – 700 001
Date: - 31.10.2018

CORRIGENDUM LETTER.

E-Tender invited vide no. P/1/ E-Tender / 40 KVA UPS/18-19 for SITC of 40 KVA UPS at 13 sites for 10 KW FM Transmitters of East Zone. It is notified that following modification have been included in the tender.

Sl. No.	For	To be Read As
1.	<u>Annexure – III sl. No. – 6 – (ii)</u> For the batteries, the agency must offer the warranty period of the OEM and it should not be less than 2 years.	<u>Annexure – III sl. No. – 6 – (ii)</u> For the batteries, the agency must offer the warranty period of the OEM and it should not be less than 3 years
2.	<u>Section – 2.0 Point No. II</u> The system should also include an in built 60 KVA Isolation Transformer along with the UPS to provide protection from electrical surges/noise (inherent and generated both) present in the input power supply	<u>Section – 2.0 Point No. II</u> The system should also include an external 60 KVA Isolation Transformer along with the UPS to provide protection from electrical surges/noise (inherent and generated both) present in the input power supply
3.	<u>Completion Period :-</u> Completion of SITC within 90 days after issuance of LOI	<u>Completion Period :-</u> Completion of SITC within 100 days after issuance of LOI


(JK. Ray) 31/10/18

Dy. Director Engg. (P)
For Addl. Director General (E)(EZ)